



Recommended Hole Dimensions - 108" Long x 72" Wide x 78" Deep with a 4" - 6" base of appropriate bedding material

NOTES

- 1" Potable Mastic Placed Between Riser and Lid
- 1.25" Brass Couplings Cast Into Both Ends (Other Sizes Available as Special Order)
- Fiber Reinforced Concrete (4000 PSI)
- #4 Rebar 12" O.C. E.W. in Lid
- 6x6 8x8 Steel Mesh in Tank

TITLE

**600 Gallon Water Cistern
(Special Order Only)**

DATE 11/15/17

REVISION 1.0

THE FAGENSTROM CO.
2101 NORTHWEST BYPASS
P.O. Box 2623
GREAT FALLS, MT 59403
WWW.FAGENSTROM.CO
406-761-5200



THE FAGENSTROM CO.

P.O. Box 2623
GREAT FALLS, MT 59403
(406) 761-5200

Recommended Cistern Installation Guidelines

1. Cisterns should be located:
 - In a non-traffic area.
 - At least 10 feet from any foundation.
 - 50 feet from wastewater treatment drain fields.
 - 25 feet from septic tanks.
 - Away from tree, root or brush zones.
 - Where there is positive drainage away from the cistern.
2. The recommended hole dimensions for our cisterns are printed on the opposite page.
3. The cistern hole should have a firm and level base of appropriate bedding material.
4. High-density insulation board can be installed on top of the cistern for an additional frost barrier.
5. The cistern must be backfilled and compacted before filling with water.
6. The access riser should be at least 12 inches above the finished grade.
7. Don't overfill the cistern to where the water goes up into the risers.
8. The cistern should be inspected and cleaned on a regular basis.